TYPE APPROVAL CERTIFICATE

This is to certify that the undernoted product(s) has/have been tested in accordance with the relevant requirements of the DNV GL Type Approval System.

Certificate No.

75 878 - 09 HH

Company

STS Sensor Technik Sirnach AG

Rütihofstrasse 8

8370 Sirnach, SWITZERLAND

Product Description

Submersible Pressure Transmitter

Intrinsically Safe Submersible Pressure Transmitter (Ex-Type)

Type

ATM.xxx/N/Ship ATM.xxx/N/Ex/Ship

Environmental Category

C, H, EMC1

Technical Data / Range of Application Possible variants (xxx): ECO or 1ST

Pressure type: gauge or absolute (vacuum) Pressure range: 0...0.1 bar up to 0...25 bar

Power supply: 24V DC (9V DC min. ... 30V DC max.)

Output signal: 4...20mA, 2-wire connection, loop-powered

Accuracy: better than ±0.25% FS (at 25°C)
Total error range: better than ±1.0% FS
Electrical connection: fixed cable

Fixing: freely suspended cable

Material: housing, diaphragm, process connection - stainless steel or titanium

seals - Viton

cable PUR or FEP - *Installation inside tank only

Degree of protection: IP68

Intrinsic Safety (ATM.xxx/N/Ex/Ship): see certificate SEV 09 ATEX 0108

Test Standard

GL Guidelines for the Performance of Type Approvals, Chapter 2 – Test Requirements for Electrical / Electronic Equipment and Systems (VI-7-2),

Edition 2012

Documents

Test Reports: STS No. 6.59(60).0867.A.PB/TBxx.doc

Test Report: STS 'Trockene Wärme' 12.03.2012 Test Reports: Mettler-Toledo No. 20091134.A02.01 and No. 20081106.A02.01

Test Report: Montena EMC No. 15'694; Ex-Cert.: SEV 09 ATEX 0108

Circuit Diagramms: 4.30.0129.C & 4.30.0139

Data Sheets: 10.00.0302, 10.00.0304

Remarks

This certificate is issued on the basis of GL Guidelines for the Performance of

Type Approvals, Chapter 1 - Procedure (VI-7-1), Edition 2007

Valid until 2019-11-09

Page

1 of 1

File No.

I.D.01

Hamburg, 2014-11-10

Type Approval Symbol

(GL)

DNV GL

Marco Rinkel

Dariusz Lesniewski